

ISBN 978-0-626-27966-0

**SANS 60099-1:1999**

Edition 1.1 and nat. amdt 1

**IEC 60099-1:1999**

Edition 3.1

Any reference to SABS IEC 60099-1 is deemed  
to be a reference to this standard  
(Government Notice No. 1373 of 8 November 2002)

# **SOUTH AFRICAN NATIONAL STANDARD**

## **Surge arresters**

### **Part 1: Non-linear resistor type gapped surge arresters for a.c systems**

This national standard is the identical implementation of IEC 60099-1:1999 and is adopted with the permission of the International Electrotechnical Commission.

**SANS 60099-1:1999**

Edition 1.1 and nat. amdt 1

**IEC 60099-1:1999**

Edition 3.1

**Table of changes**

<b>Change No.</b>	<b>Date</b>	<b>Scope</b>
IEC amdt 1	1999	Amended to change the requirements for arrester identification and for long-duration current withstand, to change the parameters for wet tests, to add limits for switching impulse sparkover voltage for heavy-duty arresters and to replace the "pressure-relief tests" with "short-circuit tests".
Nat. amdt 1	2007	Amended to change the designation from SABS to SANS, with no technical changes.

**National foreword**

This South African standard was approved by National Committee SABS SC 67E, *Electricity distribution systems and components – Electricity distribution*, in accordance with procedures of the SABS Standards Division, in compliance with annex 3 of the WTO/TBT agreement.

This SANS document was published in September 2007.

This SANS document supersedes SABS IEC 60099-1:1999 (edition 1.1).

**Reaffirmed and reprinted in February 2012.  
This document will be reviewed every five years and  
be reaffirmed, amended, revised or withdrawn.**

**NORME  
INTERNATIONALE  
INTERNATIONAL  
STANDARD**

**CEI  
IEC**

**60099-1**

**Edition 3.1**

1999-12

Edition 3:1991 consolidée par l'amendement 1:1999  
Edition 3:1991 consolidated with amendment 1:1999

---

---

**Parafoudres –**

**Partie 1:  
Parafoudres à résistance variable avec  
éclateurs pour réseaux à courant alternatif**

**Surge arresters –**

**Part 1:  
Non-linear resistor type gapped surge arresters  
for a.c. systems**

© IEC 1999 Droits de reproduction réservés — Copyright - all rights reserved

Aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'éditeur.

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission  
Telefax: +41 22 919 0300

e-mail: [inmail@iec.ch](mailto:inmail@iec.ch)

3, rue de Varembeé Geneva, Switzerland  
IEC web site <http://www.iec.ch>

---

---



Commission Electrotechnique Internationale  
International Electrotechnical Commission  
Международная Электротехническая Комиссия

---

---

CODE PRIX  
PRICE CODE

**X**

*Pour prix, voir catalogue en vigueur  
For price, see current catalogue*

## CONTENTS

	Page
FOREWORD .....	7
INTRODUCTION .....	9
Clause	
SECTION 1: GENERAL	
1.1 Scope.....	11
1.2 Normative references .....	11
SECTION 2: DEFINITIONS	
SECTION 3: IDENTIFICATION AND CLASSIFICATION	
3.1 Arrester identification.....	21
3.2 Arrester classification .....	23
SECTION 4: STANDARD RATINGS	
4.1 Standard voltage ratings .....	23
4.2 Standard rated frequencies.....	23
4.3 Standard nominal discharge currents .....	23
4.4 Service conditions .....	25
4.4.1 Normal service conditions .....	25
4.4.2 Abnormal service conditions.....	25
SECTION 5: REQUIREMENTS	
5.1 Power-frequency sparkover voltage .....	25
5.2 Standard lightning impulse sparkover voltage .....	25
5.3 Front-of-wave impulse sparkover voltage .....	25
5.4 Switching impulse sparkover voltage.....	25
5.5 Lightning impulse residual voltage .....	27
5.6 Switching impulse residual voltage.....	27
5.7 High-current impulse withstand .....	27
5.8 Long-duration current withstand.....	27
5.9 Operating-duty.....	27
5.10 Pressure-relief.....	27
5.11 Disconnectors .....	29
5.11.1 Disconnector withstand .....	29
5.11.2 Disconnector operation .....	29
SECTION 6: GENERAL TESTING PROCEDURE	
6.1 Test samples and measurements .....	29
6.2 Power-frequency voltage tests .....	29
6.3 Wet tests.....	29
6.4 Artificial-pollution tests .....	31

Clause	Page
<b>SECTION 7: ROUTINE AND ACCEPTANCE TESTS</b>	
7.1	Routine tests ..... 31
7.2	Acceptance tests ..... 31
<b>SECTION 8: TYPE TESTS (DESIGN TESTS)</b>	
8.1	General ..... 33
8.2	Power-frequency voltage sparkover tests ..... 35
8.3	Voltage impulse sparkover tests ..... 37
8.3.1	General..... 37
8.3.2	Standard lightning impulse sparkover test..... 37
8.3.3	Lightning impulse sparkover-voltage/time curve test ..... 39
8.3.4	Front-of-wave impulse sparkover test..... 39
8.3.5	Switching impulse sparkover-voltage/time curve test ..... 41
8.4	Measurement of residual voltage ..... 43
8.4.1	Lightning impulse residual voltage ..... 43
8.4.2	Switching impulse residual voltage ..... 43
8.5	Current impulse withstand tests ..... 47
8.5.1	General..... 47
8.5.2	High-current impulse test ..... 47
8.5.3	Long-duration current impulse test ..... 49
8.6	Operating-duty test..... 53
8.7	Short-circuit tests ..... 57
8.7.1	General..... 57
8.7.2	Preparation of the test samples ..... 57
8.7.3	Mounting of the test sample ..... 61
8.7.4	Evaluation of test results ..... 67
8.7.5	High current short-circuit tests..... 67
8.7.6	Low current short-circuit test ..... 71
8.8	Tests of arrester disconnectors..... 71
8.8.1	General..... 71
8.8.2	Current impulse withstand and operating-duty tests ..... 71
8.8.3	Disconnecter operation ..... 73
Annex A (normative) Abnormal service conditions ..... 79	
Annex B (informative) Typical information given with enquiries and tenders ..... 81	
Annex C (informative) Selection of the long-duration discharge class of heavy-duty arresters..... 85	
Annex D (informative) Typical circuit for a distributed-constant impulse generator for the long-duration current impulse test according to 8.5.3..... 87	
Annex E (informative) Typical circuit for operating-duty test according to 8.6 ..... 91	