

ISBN 978-0-626-34703-1

SANS 5861-2:2006

Edition 2.1

Any reference to SABS SM 861-2 is deemed
to be a reference to this standard
(Government Notice No. 1373 of 8 November 2002)

SOUTH AFRICAN NATIONAL STANDARD

Concrete tests

Part 2: Sampling of freshly mixed concrete

This page has been left blank intentionally



COPYRIGHT PROTECTED DOCUMENT

© SABS

In terms of the Standards Act 8 of 2008, the copyright in all South African National Standards or any other publications published by the SABS Standards Division, vests in the SABS. Any use of South African National Standards is limited to use specifically prescribed by the SABS. In the case of a South African National Standard based on an international standard, ownership of the copyright vests in the organization from which the SABS adopted the standard, whether it be under licence or membership agreement. The SABS is obliged to protect such copyright and is authorized to make the relevant international organization aware of any misuse thereof. Unless exemption has been granted, no extract or full text of any South African National Standard may be copied, reproduced, stored in a retrieval system or transmitted in any form or by any means without prior written permission from the SABS Standards Division. This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any purpose other than implementation, prior written permission must be obtained.

Details, advice and limitations of use can be obtained from the Manager: Standards Sales and Information Services. Tel: +27 (0) 12 428 6883 email: sales@sabs.co.za

SABS – Standards Division

The objective of the SABS Standards Division is to develop, promote and maintain South African National Standards. This objective is incorporated in the Standards Act, 2008 (Act No. 8 of 2008).

The SABS continuously strives to improve the quality of its products and services and would therefore be grateful if anyone finding an inaccuracy or ambiguity while using this standard would inform the secretary of the technical committee responsible, the identity of which can be found in the foreword.

Buying Standards

Contact the Sales Office for South African and international standards, which are available in both electronic and hard copy format. Tel: +27 (0) 12 428 6883 email: sales@sabs.co.za

South African National Standards are also available online from the SABS Webstore www.store.sabs.co.za

Information on Standards

SABS Customer Services provide comprehensive standards-related information on national, regional and international standards. Tel: +27 (0) 12 428 7911 / 0861 27 7227 email: info@sabs.co.za

SANS 5861-2:2006
Edition 2.1

Table of changes

Change No.	Date	Scope
Amdt 1	2006	Amended to change the designation of SABS standards to SANS standards, with no technical changes.

Foreword

This South African standard was prepared by National Committee SABS/TC 081/SC 01, *Construction materials, products and test methods – Cement, lime and concrete*, in accordance with procedures of the SABS, in compliance with annex 3 of the WTO/TBT agreement.

This edition is technically identical to the first revision (SABS SM 861-2:1994).

SANS 5861 consists of the following parts, under the general title, *Concrete tests*:

Part 1: Mixing fresh concrete in the laboratory.

Part 2: Sampling of freshly mixed concrete.

Part 3: Making and curing of test specimens.

Compliance with this document cannot confer immunity from legal obligations.

<p>Reaffirmed and reprinted in July 2017. This document will be reviewed every five years and be reaffirmed, amended, revised or withdrawn.</p>
--

Concrete tests

Part 2: Sampling of freshly mixed concrete

1 Scope

This part of SANS 5861 covers procedures for obtaining samples of freshly mixed concrete that have been delivered in measured or measurable quantities to a site or mixed in a laboratory, and on which tests to determine compliance with the requirements of the relevant standard(s) are to be performed.

2 Definitions

For the purposes of this part of SANS 5861, the following definitions apply:

2.1

batch

unit or a defined quantity of freshly mixed concrete that is to be sampled

2.2

increment

quantity of concrete taken by the single operation of a scoop

2.3

sample

quantity of concrete that is representative of a batch, that usually consists of a number of increments and of which the properties are to be determined

3 Apparatus

3.1 Scoops, that are fitted with handles, are made of a metal that is not readily attacked by cement, and are of known capacity so that the volume of concrete taken is known.

3.1.1 For sampling from a moving stream of concrete, use a box-shaped scoop that has a handle long enough to be held safely and easily with both hands, and that has side-walls that are high enough to prevent excessive spilling of concrete.

3.1.2 For sampling from static concrete, use a scoop that is in the form of a shovel that has a high back and high side-walls, to facilitate penetration into the concrete.

3.2 Containers, that are of a size suitable for collecting the required increments of concrete, and that have adequate rigidity, are watertight and are made of a material that is not readily attacked by cement.